



Jim Doyle, Governor
Mary P. Burke, Secretary

January 6, 2006

ARLYN STENCIL
R5442 CTY RD. H
EDGAR WI 54426

Re: Description: SEWAGE TANK, SITE CONSTRUCTED
Manufacturer: ARLYN STENCIL
Product Name: HOLDING
Model Number(s): A-4211 (80" L.L., 52.64 GAL/IN., 120" MAX. DEPTH OF BURY)
B-4876 (80" L.L., 60.95 GAL/IN., 120" MAX. DEPTH OF BURY)
C-6206 (80" L.L., 77.53 GAL/IN., 120" MAX. DEPTH OF BURY)
Product File No: 20050916

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of January 2011.

This approval is contingent upon compliance with the following stipulation(s):

- This tank must be designed to withstand the pressures to which it will be subjected.
- This product must be installed with a Spartan Chemical Co., Inc. model 9111 Vent T Connector fitting permanently connected to the inlet of the hose serving this product when the product is not served by a separate water supply connection.
- The manufacturer must keep a set of plans and specifications for this product bearing the department's stamp of approval. The plans and specifications must be open to inspection by an authorized representative of the department.

This approval supersedes the approval issued on INSERT DATE under product file number 20002144.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20002144

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wi.gov